

Size	Nk Vel	300	400	500	600	700	800	900	1000
	Pv	0.006	0.010	0.016	0.022	0.031	0.04	0.050	0.062
09x06	CFM	113	150	188	225	263	300	338	375
	Pt	0.042	0.075	0.116	0.168	0.228	0.298	0.376	0.465
	Throws	6-20	9-27	11-32	14-35	16-38	18-40	20-42	22-45
	NC	-	-	13	19	25	30	34	38
12x06	CFM	150	200	250	300	350	400	450	500
	Pt	0.038	0.068	0.106	0.152	0.207	0.271	0.341	0.422
	Throws	9-24	11-30	15-36	17-39	21-42	23-45	24-47	27-50
	NC	-	-	13	19	25	30	34	38
	CFM	188	250	313	375	438	500	563	625
4500	Pt	0.037	0.063	0.098	0.141	0.192	0.250	0.317	0.391
15x06	Throws	11-29	14-35	18-40	22-44	26-47	28-51	29-53	32-57
	NC	-	-	14	20	26	31	35	39
	CFM	225	300	375	450	525	600	675	750
40.00	Pt	0.033	0.059	0.092	0.133	0.180	0.236	0.299	0.369
18x06	Throws	14-34	17-40	22-45	26-48	30-52	33-56	34-59	36-63
	NC	-	-	15	21	17	31	36	39
	CFM	300	400	500	600	700	800	900	1000
04.00	Pt	0.030	0.053	0.083	0.120	0.164	0.213	0.271	0.334
24x06	Throws	17-39	23-45	28-51	32-56	35-60	36-64	40-68	41-72
	NC	-	-	14	20	25	30	35	38
	CFM	375	500	625	750	875	1000	1125	1250
20,406	Pt	0.028	0.049	0.078	0.112	0.151	0.198	0.251	0.309
30x06	Throws	21-45	28-51	33-57	36-63	39-68	41-72	45-76	46-81
	NC	-	-	14	20	25	30	34	38
	CFM	450	600	750	900	1050	1200	1350	1500
36,06	Pt	0.026	0.047	0.073	0.105	0.143	0.186	0.236	0.291
36x06	Throws	26-50	33-58	36-64	40-71	44-76	47-82	51-87	52-90
	NC	-	-	16	22	27	32	36	40
48x06	CFM	1000	1334	1667	2000	2334	2667	3000	3334
	Pt	0.024	0.043	0.066	0.095	0.129	0.169	0.214	0.264
	Throws	30-54	36-65	41-71	45-80	48-84	53-92	57-98	59-101
	NC	-	11	17	24	29	34	38	42
60x06	CFM	1250	1667	2084	2500	2917	3334	3750	4167
	Pt	0.022	0.039	0.061	0.088	0.120	0.157	0.199	0.244
	Throws	36-62	41-71	46-80	51-88	54-94	58-101	62-107	65-113
	NC	-	12	19	26	31	36	40	44



									PACTORING
Size	Nk Vel	300	400	500	600	700	800	900	1000
	Pv	0.006	0.010	0.016	0.022	0.031	0.04	0.050	0.062
20x10	CFM	417	556	695	834	973	1112	1250	1389
	Pt	0.026	0.047	0.074	0.107	0.145	0.189	0.240	0.292
	Throws	22-46	30-53	34-59	38-64	40-70	44-75	46-78	48-83
	NC	-	-	16	22	27	32	36	40
30x10	CFM	625	834	1042	1250	1459	1667	1875	2084
	Pt	0.023	0.042	0.065	0.094	0.128	0.167	0.211	0.261
30.10	Throws	28-54	35-63	40-70	23-77	28-83	52-88	54-93	57-99
	NC	-	10	17	23	28	30	38	41
	CFM	834	1112	1389	1667	1945	2223	2500	2778
4010	Pt	0.021	0.037	0.058	0.083	0.114	0.149	0.188	0.233
40x10	Throws	34-63	41-72	46-81	52-90	57-96	60-101	63-107	65-114
	NC	-	11	18	24	29	32	39	42
	CFM	1042	1389	1737	2084	2431	2778	3125	3473
	Pt	0.019	0.034	0.053	0.077	0.105	0.137	0.173	0.213
50X10	Throws	41-71	47-82	53-92	58-101	63-108	68-116	71-123	75-130
	NC	-	12	29	25	31	36	40	44
	CFM	1250	1667	2084	2500	2917	3334	3750	4167
	Pt	0.018	0.033	0.051	0.075	0.101	0.132	0.167	0.207
60X10	Throws	44-77	51-90	58-100	63-111	69-119	74-126	77-135	82-142
	NC	_	13	20	26	31	37	40	45
	CFM	1459	1945	2431	2917	3403	3889	4375	4862
	Pt	0.017	0.031	0.049	0.070	0.095	0.124	0.157	0.194
70X10	Throws	48-84	57-98	63-108	69-119	75-129	80-137	84-146	89-153
	NC	-	14	21	27	32	37	41	45
	CFM	500	667	834	1000	1167	1334	1500	1667
	Pt	0.024	0.043	0.066	0.095	0.129	0.169	0.214	0.264
20X12	Throws	27-50	33-58	38-64	41-70	44-76	47-81	50-86	52-90
	NC	_	-	16	23	38	33	37	41
	CFM	750	1000	1250	1500	1750	2000	2250	2500
201442	Pt	0.022	0.039	0.061	0.088	0.120	0.157	0.199	0.244
30X12	Throws	34-60	40-70	45-77	48-84	52-92	57-98	59-104	62-110
	NC	-	11	18	24	29	34	38	42
	CFM	1000	1334	1667	2000	2334	2667	3000	3334
40X12	Pt	0.019	0.035	0.054	0.079	0.108	0.140	0.178	0.219
	Throws	40-70	47-81	52-90	57-99	62-106	66-113	70-120	74-128
	NC	-	12	19	25	31	35	40	43
50X12	CFM	1250	1667	2084	2500	2917	3334	3750	4167
	Pt	0.018	0.032	0.050	0.073	0.098	0.128	0.163	0.201
	Throws	45-77	52-89	57-100	63-108	68-74	74-125	77-134	81-141
	NC	-	13	20	26	31	36	41	44
	CFM	1500	200	2500	3000	3500	4000	4500	5000
00)// 0	Pt	0.017	0.031	0.485	0.070	0.095	0.124	0.157	0.194
60X12	Throws	50.84	57-98	63-110	69-118	74-130	81-137	84-147	90-154
	NC	-	14	21	27	32	37	42	45



Size	Nk Vel	300	400	500	600	4667	800	900	1000
	Pv	0.006	0.010	0.016	0.022	0.031	0.04	0.050	0.062
70x12	CFM	1750	2334	2917	3500	4084	4667	5250	5834
	Pt	0.016	0.029	0.046	0.066	0.089	0.116	0.147	0.182
	Throws	53-92	62-106	69-118	75-130	81-141	87-150	92-159	96-167
	NC	ı	15	22	28	33	38	42	46
15x15	CFM	469	625	782	938	1094	1250	1407	1563
	Pt	0.024	0.044	0.068	0.097	0.133	0.173	0.219	0.271
10,710	Throws	23-48	30-56	36-63	40-69	42-74	46-78	48-83	51-88
	NC	-	-	16	23	28	33	37	41
	CFM	625	834	1042	1250	1459	1667	1875	2084
20x15	Pt	0.021	0.042	0.064	0.092	0.127	0.165	0.210	0.257
2000	Throws	28-56	35-64	41-72	46-80	50-86	53-92	56-96	59-102
	NC	-	10	17	24	29	33	37	42
	CFM	938	1250	1563	1875	2188	2500	2813	3125
30x15	Pt	0.020	0.037	0.057	0.081	0.112	0.146	0.184	0.227
SONTO	Throws	33-63	40-72	47-82	53-90	57-98	60-105	63-110	68-117
	NC	-	11	18	25	30	34	38	43
	CFM	1094	1459	1823	2188	2553	2917	3282	3646
35x15	Pt	0.019	0.034	0.053	0.077	0.105	0.137	0.173	0.213
55.1.15	Throws	39-70	46-81	19-92	59-101	64-110	68-118	71-123	76-131
	NC	-	12	19	26	30	35	39	43
	CFM	1250	1667	2084	2500	2917	3334	3750	4167
40x15	Pt	0.030	0.053	0.083	0.120	0.164	0.213	0.271	0.334
	Throws	17-39	23-45	28-51	32-56	35-60	36-64	40-68	41-72
	NC	-	-	14	20	25	30	35	38
	CFM	1563	2084	2605	3125	3646	4167	4688	5209
50x15	Pt	0.017	0.030	0.047	0.067	0.091	0.119	0.154	0.186
COXIO	Throws	51-87	58-100	65-112	71-123	77-132	82-142	87-150	92-159
	NC	-	14	21	27	32	37	41	45
60x15	CFM	1875	2500	3125	3750	4375	5000	5625	6250
	Pt	0.016	0.029	0.045	0.065	0.088	0.115	0.146	0.179
	Throws	56-95	64-110	71-122	78-134	84-144	89-154	95-165	100-176
	NC	-	14	22	28	33	38	42	46
70x15	CFM	2188	2917	3646	4375	5105	5834	6563	7292
	Pt	0.016	0.027	0.043	0.061	0.083	0.109	0.137	0.170
	Throws	59-102	69-118	76-132	84-144	90-156	96-167	102-178	108-186
	NC	-	15	23	28	34	39	43	47



Data based on units tested at 0° Blade Defletion. See chart below for other Blade Deflections.

Deflection	NC	Throws	Pt
15°	+4	x .85	x 1.2
30°	+8	x .69	x 1.8

#### PERFORMANCE NOTES FOR SERIES DL

All Data was tested in accordance with ANSI/ASHRAE 70-2006

### DEFINITION OF UNITS:

CFM Air volume is cubic feet per minute

Nk Vel Neck Velocity is the airstream velocity in the duct just before it reaches the supply outlet; measured in feet per

minute

NC Noise Criteria based on a room absorption of 10 dB, re: 10-12 watts [ NC les than 10 (-)]

Throw Throw distance in feet are for terminal velocities of 150 and 50 fpm respectively

Ps Static pressure is in inches of water